

## FINAL REPORT

Report ID : 209422

### Report Information

**Submitting Organisation** 00121988 : Saier Brothers Trading Pty Ltd  
**Account :** 143097 : Saier Brother Trading Pty Ltd  
**AWQC Reference :** 143097-2017-CSR-1 : Prod Test: Silicone Sealant  
**Project Reference :** PT-3143  
**Product Designation :** Sarlsson 168 - All Purpose Silicone Sealant (Clear)  
**Composition of Product :** Silicone.  
**Product Manufacturer :** Saier Time, Beijing, CHINA.  
**Use of Product :** In-Line/Sealing Compound.  
**Sample Selection:** As provided by the submitting organisation.  
**Testing Requested :** **AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**  
**Product Type :** Composite  
**Samples :** Samples were prepared and controlled as described in Appendix A of AS/NZS 4020: 2005  
**Extracts :** Extracts were prepared as described in Appendix C, D, E, F, G, H.  
**Project Completion Date** 10-Aug-2017  
**Project Comment :** The results presented herein demonstrate compliance of the Sarlsson 168 - All Purpose Silicone Sealant (Clear) to AS/NZS 4020 when exposed at area to volume ratios up to 2500 mm<sup>2</sup>/L at 20°C ± 2°C.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Michael Glasson  
APPROVED SIGNATORY



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### Summary of Results

APPENDIX	RESULTS
C – Taste of Water Extract	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
D – Appearance of Water Extract	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
E – Growth of Aquatic Micro-organisms	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
F – Cytotoxic Activity of Water Extract	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
G – Mutagenic Activity of Water Extract	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
H – Extraction of Metals	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.

### Test Methods

Test(s) in Appendix	AWQC Test Method	Reference Method
C	T0320-01	AS/NZS 4020:2005
D	TO029-01 & TO018-01	APHA 2130b
E	TO014-03	APHA 4500 O C
F	TM-001	AS/NZS 4020:2005
G	TM-002	AS/NZS 4020:2005
H	TIC-006	EPA 200.8

#### Summary Comment :

The sealant was applied and cured for seven days at 20°C prior to commencement of testing (See attachment for further information).

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.2 Taste of Water Extract

Sample Description	The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm <sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.
Extraction Temperature	20°C ± 2°C.
Test Method	Taste of Water Extract (Appendix C)
Test Information	
Scaling Factor	Not applied.
Results	Not detected.
Evaluation	The product passed the requirements of clause 6.2 when tested at an exposure of 2500 mm <sup>2</sup> per Litre.
Number of Samples	2.
Test Comment	Not applicable.



Peter Christopoulos  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.3 Appearance of Water Extract

**Sample Description** The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Appearance of Water Extract (Appendix D)

**Scaling Factor** Not applied.

#### Results

	<u>Test (- Blank)</u>	<u>Maximum Allowed</u>	<u>Units</u>
Colour	<1	5	HU
Turbidity	<0.1	0.5	NTU

**Evaluation** The product passed the requirements of clause 6.3 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.



Andrew Ford  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.4 Growth of Aquatic Micro-organisms

**Sample Description** The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of test water.

**Test Method** Growth of Aquatic Micro-organisms (Appendix E)

**Inoculum** The volume of the inoculum was 100 mL

**Scaling Factor** Not applied.

<b>Results</b>	Mean Dissolved Oxygen	Control	7.8 mg/L
	Mean Dissolved Oxygen Differenc	Positive Reference	5.6 mg/L
		Negative Reference	<0.1 mg/L
		Test	1.10 mg/L

**Evaluation** The product passed the requirements of clause 6.4 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.



Thuy Diep  
APPROVED SIGNATORY



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.5 Cytotoxic Activity of Water Extract

**Sample Description** The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Cytotoxic Activity of Water Extract (Appendix F)

**Scaling Factor** Not applied.

**Results** Non-cytotoxic.

**Evaluation** The product passed the requirements of clause 6.5 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** The test extracts and blank extracts were used to prepare nutrient growth medium and subsequently used to grow a cell line (ATCC Number CCL 81) in the analysis. In addition zinc sulphate (0.4 mmol) was used for the positive control in the analysis.



Brendon King  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.6 Mutagenic Activity of Water Extract

**Sample Description** The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Mutagenic Activity of Water Extract (Appendix G)

**Scaling Factor** Not applied.

#### Results

Bacteria Strain	Number of Revertants per Plate			
	S9	Blank	Sample Extract	Positive Controls
<i>Salmonella typhimurium</i> TA98	-	53, 41, 39	32, 39, 42	3023, 3069, 2896
Mean ± Standard deviation		44.3 ± 7.6	37.7 ± 5.1	2996.0 ± 89.6
	+	47, 54, 62	41, 42, 46	2390, 2876, 2830
Mean ± Standard deviation		54.3 ± 7.5	43.0 ± 2.6	2698.7 ± 268.3
<i>Salmonella typhimurium</i> TA100	-	471, 382, 470	447, 452, 481	1263, 1167, 1199
Mean ± Standard deviation		441.0 ± 51.1	460.0 ± 18.4	1209.7 ± 48.9
	+	277, 251, 267	322, 266, 290	1681, 1678, 1665
Mean ± Standard deviation		265.0 ± 13.1	292.7 ± 28.1	1674.7 ± 8.5
<i>Salmonella typhimurium</i> TA102	-	391, 452, 460	510, 423, 479	2806, 2481, 2070
Mean ± Standard deviation		434.3 ± 37.7	470.7 ± 44.1	2452.3 ± 368.8
	+	282, 301, 370	272, 342, 332	1756, 1633, 1512
Mean ± Standard deviation		317.7 ± 46.3	315.3 ± 37.9	1633.7 ± 122.0

**Comments** S9 was used as a metabolic activator. NPD (4-nitro-o-phenylenediamine), Azide, and Mitomycin C are specific positive controls for strains TA98, TA100 and TA102 respectively while 2 - AF (2-aminofluorene) when used in conjunction with S9 is a positive control for both TA98 and TA100

**Evaluation** The product passed the requirements of clause 6.6 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.



Peter Christopoulos  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025

## FINAL REPORT

Report ID : 209422

### CLAUSE 6.7 Extraction of Metals

**Sample Description** The sample consisted of one panel (coated on a single side) with dimensions 25 mm x 100 mm providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Extraction of Metals (Appendix H)

**Scaling Factor** Not applied.

**Method of Analysis** All methods used to determine concentrations of metals are based on those described in the 21st edition of Standard Methods for the Examination of Water and Wastewater published by the APHA, AWWA and WEF (2005). The methods have been adapted for the instrumentation in use at the Australian Water Quality Centre. Concentration of the metals described in Table 2 of the AS/NZS 4020:2005 are determined as follows:

Antimony, Arsenic, Barium, Cadmium, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Selenium and Silver by Inductively Coupled Plasma Mass

Results	Limit of Reporting mg/L	Blank mg/L	Test 1 mg/L	Test 2 mg/L	Max Allowed mg/L
<b>Final Extract</b>					
Antimony	0.0005	<0.0005	0.0023	0.0021	0.003
Arsenic	0.0003	<0.0003	<0.0003	<0.0003	0.007
Barium	0.0005	<0.0005	<0.0005	<0.0005	0.7
Cadmium	0.0001	<0.0001	<0.0001	<0.0001	0.002
Chromium	0.0001	<0.0001	<0.0001	<0.0001	0.05
Copper	0.0001	<0.0001	<0.0001	<0.0001	2.0
Lead	0.0001	<0.0001	<0.0001	<0.0001	0.01
Mercury	0.00003	0.00005	<0.00003	<0.00003	0.001
Molybdenum	0.0001	<0.0001	<0.0001	<0.0001	0.05
Nickel	0.0001	<0.0001	<0.0001	<0.0001	0.02
Selenium	0.0001	<0.0001	<0.0001	<0.0001	0.01
Silver	0.00003	<0.00003	<0.00003	<0.00003	0.1

**Evaluation** The product passed the requirements of clause 6.7 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

  
Dzung Bui  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025



# Sarlsson 168 All-Purpose Silicone Sealant

## Safety Data Sheet

### Hazardous Substance, NON-Dangerous Goods

#### 1. MATERIAL AND SUPPLY COMPANY IDENTIFICATION

**Product name:** Sarlsson 168 All-Purpose Silicone Sealant

**Recommended use:** Adhesive/Glue

**Supplier:** Saier Brothers Trading Ltd. Pty.

**ABN:**

**Street Address:** 86 Hassall Street, Wetherill Park NSW 2164 Australia

**Telephone:**

**Emergency:** 0449911939

#### 2. HAZARDS IDENTIFICATION

This material is hazardous according to health criteria of Safe Work Australia.



#### Signal Word

Warning

#### Hazard Classifications

Skin Corrosion/Irritation - Category 2

Serious Eye Damage/Irritation - Category 2A

Sensitisation - Skin - Category 1

Carcinogenicity - Category 2

#### Hazard Statements

H315 Causes skin irritation.

#### Australian Water Quality Centre

Report Number.....209422.....

Date.....10/8/2017.....

Document reviewed by.....MICHAEL GNASSON.....

Signature.....M. Gnanou.....

- |      |                                      |
|------|--------------------------------------|
| H317 | May cause an allergic skin reaction. |
| H319 | Causes serious eye irritation.       |
| H351 | Suspected of causing cancer.         |

#### **Prevention Precautionary Statements**

- |      |   |
|------|---|
| P102 | Keep out of reach of children.  |
| P103 | Read label before use.  |
| P201 | Obtain special instructions before use.                                   |
| P202 | Do not handle until all safety precautions have been read and understood. |
| P261 | Avoid breathing dust, fume, gas, mist, vapours or spray.                  |
| P264 | Wash hands, face and all exposed skin thoroughly after handling.          |
| P272 | Contaminated work clothing should not be allowed out of the workplace.    |
| P281 | Use personal protective equipment as required.                            |

#### **Response Precautionary Statements**

- |                |  |
|----------------|--|
| P101           | IF medical advice is needed, have product container or label at hand.  |
| P302+P352      | IF ON SKIN: Wash with plenty of soap and water.  |
| P305+P351+P338 | IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. |
| P308+P313      | IF exposed or concerned: Get medical advice/attention.   |
| P333+P313      | IF skin irritation or rash occurs: Get medical advice/attention.   |
| P337+P313      | IF eye irritation persists: Get medical advice/attention.  |
| P362           | Take off contaminated clothing and wash before reuse.  |
| P363           | Wash contaminated clothing before reuse.   |

#### **Storage Precautionary Statement**

- |      |                  |
|------|------------------|
| P405 | Store locked up. |
|------|------------------|

#### **Disposal Precautionary Statement**

- |      |   |
|------|---|
| P501 | Dispose of contents/container in accordance with local, regional, national and international regulations. |
|------|---|

**Poison Schedule:** Not Applicable

#### **DANGEROUS GOOD CLASSIFICATION**

Not Classified as Dangerous Goods by the Criteria of the "Australian Code for the Transport of Dangerous Goods by Road & Rail" and the "New Zealand NZS5433: Transport of Dangerous Goods on Land".

#### **3. FIRST AID MEASURES**

If poisoning occurs, contact a doctor or Poisons Information Centre (Phone Australia 131 126,

New  
Zealand 0800 764 766).

**Inhalation:** Remove victim from exposure - avoid becoming a casualty. Remove contaminated clothing and loosen remaining clothing. Allow patient to assume most comfortable position and keep warm. Keep at rest until fully recovered. Seek medical advice if effects persist.

**Skin Contact:** Effects may be delayed. If skin or hair contact occurs, immediately remove contaminated clothing and flush skin and hair with running water. Continue flushing with water until advised to stop by the Poisons Information Centre or a Doctor; or for 15 minutes and transport to Doctor or Hospital.

**Eye contact:** If in eyes, hold eyelids apart and flush the eyes continuously with running water. Continue flushing until advised to stop by the Poisons Information Centre or a Doctor; or for at least 15 minutes and transport to Doctor or Hospital.

**Ingestion:** Rinse mouth with water. If swallowed, do NOT induce vomiting. Give a glass of water to drink. Never give anything by the mouth to an unconscious patient. If vomiting occurs give further water. Seek medical advice.

**Notes to physician:** Treat symptomatically. Effects may be delayed.

#### **4. FIRE FIGHTING MEASURES**

**Hazchem Code:** Not applicable.

**Suitable extinguishing media:** If material is involved in a fire use water fog (or if unavailable fine water spray), alcohol resistant foam, standard foam, dry agent (carbon dioxide, dry chemical powder).

**Specific hazards:** Combustible material.

**Fire fighting further advice:** On burning or decomposing may emit toxic fumes. Fire fighters to Wear selfcontained breathing apparatus and suitable protective clothing if risk of exposure to vapour or products of combustion or decomposition.

#### **5. ACCIDENTAL RELEASE MEASURES**

##### **SMALL SPILLS**

Wear protective equipment to prevent skin and eye contamination. Avoid inhalation of vapours or dust. Wipe up with absorbent (clean rag or paper towels). Collect and seal in properly labelled

eating, drinking or using the toilet. Wash contaminated clothing and other protective equipment before storing or re-using.

**Hygiene measures:** Keep away from food, drink and animal feeding stuffs. When using do not eat,  
drink or smoke. Wash hands prior to eating, drinking or smoking. Avoid contact with clothing.  
Avoid  
eye contact and skin contact. Avoid inhalation of dust. Ensure that eyewash stations and safety showers are close to the workstation location.

## 8. PHYSICAL AND CHEMICAL PROPERTIES

Form:	Paste
Colour:	Various
Odour:	Characteristic
Solubility:	N Av
Density:	0.98 g/cm <sup>3</sup>
Relative Vapour Density (air=1):	>1
Vapour Pressure (20 °C):	N Av
Flash Point (°C):	N App
Flammability Limits (%):	N App
Autoignition Temperature (°C):	N Av
Melting Point/Range (°C):	N Av
Boiling Point/Range (°C):	N Av
pH:	N App
Viscosity:	150,000 - 250,000 mPa.s
Total VOC (g/Litre):	N Av

(Typical values only - consult specification sheet) N Av = Not available, N App = Not applicable

## 9. STABILITY AND REACTIVITY

**Chemical stability:** This material is thermally stable when stored and used as directed.

**Conditions to avoid:** Elevated temperatures and sources of ignition.

**Incompatible materials:** Oxidising agents.

**Hazardous decomposition products:** Oxides of carbon and nitrogen, smoke and other toxic fumes.

**Hazardous reactions:** No known hazardous reactions

## 10. TOXICOLOGICAL INFORMATION

No adverse health effects expected if the product is handled in accordance with this Safety Data Sheet and the product label. Symptoms or effects that may arise if the product is mishandled and overexposure occurs are:

### Acute Effects

**Inhalation:** Material may be an irritant to mucous membranes and respiratory tract.

**Skin contact:** Contact with skin will result in irritation. A skin sensitiser. Repeated or prolonged skin

contact may lead to allergic contact dermatitis.

**Ingestion:** Swallowing can result in nausea, vomiting and irritation of the gastrointestinal tract.

**Eye contact:** An eye irritant. Exposure to the dust may cause discomfort due to particulate nature.

May cause physical irritation to the eyes.

#### **Acute toxicity**

**Inhalation:** This material has been classified as non-hazardous. Acute toxicity estimate (based on ingredients): >5 mg/L

**Skin contact:** This material has been classified as non-hazardous. Acute toxicity estimate (based on

ingredients): >2,000 mg/Kg

**Ingestion:** This material has been classified as non-hazardous. Acute toxicity estimate (based on ingredients): >2,000 mg/Kg

**Corrosion/Irritancy:** Eye: this material has been classified as a Category 2A Hazard (reversible effects to eyes). Skin: this material has been classified as a Category 2 Hazard (reversible effects to

skin).

**Sensitisation:** Inhalation: this material has been classified as not a respiratory sensitiser. Skin: this material has been classified as a Category 1 Hazard (skin sensitiser).

**Aspiration hazard:** This material has been classified as non-hazardous.

**Specific target organ toxicity (single exposure):** This material has been classified as non-hazardous.

#### **Chronic Toxicity**

**Mutagenicity:** This material has been classified as non-hazardous.

**Carcinogenicity:** This material has been classified as a Category 2 Hazard.

**Reproductive toxicity (including via lactation):** This material has been classified as non-hazardous.

**Specific target organ toxicity (repeat exposure):** This material has been classified as non-hazardous.

### **11. ECOLOGICAL INFORMATION**

Avoid contaminating waterways.

**Acute aquatic hazard:** This material has been classified as non-hazardous. Acute toxicity estimate (based on ingredients): >100 mg/L

**Long-term aquatic hazard:** This material has been classified as non-hazardous. Non-rapidly or rapidly degradable substance for which there are adequate chronic toxicity data available OR in the

absence of chronic toxicity data, Acute toxicity estimate (based on ingredients): >100 mg/L,  
where

the substance is not rapidly degradable and/or BCF < 500 and/or log Kow < 4.

**Ecotoxicity:** No information available.

**Persistence and degradability:** No information available.

**Bioaccumulative potential:** No information available.

**Mobility:** No information available.

## **12. DISPOSAL CONSIDERATIONS**

Persons conducting disposal, recycling or reclamation activities should ensure that appropriate personal protection equipment is used, see "Section 8. Exposure Controls and Personal Protection" of this SDS.

If possible material and its container should be recycled. If material or container cannot be recycled, dispose in accordance with local, regional, national and international Regulations.

## **13. TRANSPORT INFORMATION**

### **ROAD AND RAIL TRANSPORT**

Not Classified as Dangerous Goods by the criteria of the "Australian Code for the Transport of Dangerous Goods by Road & Rail" and the "New Zealand NZS5433: Transport of Dangerous Goods on Land".

### **MARINE TRANSPORT**

Not classified as Dangerous Goods by the criteria of the International Maritime Dangerous Goods Code (IMDG Code) for transport by sea.

### **AIR TRANSPORT**

Not classified as Dangerous Goods by the criteria of the International Air Transport Association (IATA) Dangerous Goods Regulations for transport by air.

TDS

## **Sarlsson 168 All-Purpose Silicone Sealant**

### **Description**

Sarlsson 168 silicone sealant is a one component, non-flowing, neutral cure, mid modulus sealant. It cures by absorption of atmospheric moisture to form a flexible and durable elastomeric seal.

### **Features**

- Good adhesion to galvanising, zincalume and painted surfaces
- Good UV, weathering, ozone, vibration, moisture and temperature resistance
- Good adhesion to glazed ceramic, enamel surfaces, fibreglass, aluminium and some plastics. Good properties against discolouring
- Will not slump in typical construction joints

### **Recommended Uses**

- Metal fabrication
- Metal roofing
- Flashing
- Roof & gutters
- Perimeter seals between aluminium window frames and brick and masonry
- Bathroom and Kitchen
- General purpose applications

### **One Part System**

- Being a one-part sealant Sarlsson 168 All-Purpose offers the confidences of consistent even cure. It also improves operator productivity, as time is not lost mixing the product, is easy to use in difficult locations, and can be applied out of a standard cartridge gun.

### **Long Life Reliability**

- Sarlsson 168 All-Purpose has excellent natural ageing stability. It will maintain its elastomeric joint sealant properties permanently, will not crack or crumble even under harsh conditions and temperature extremes.

## Characteristics

### System Properties

Property	Mean Result Achieved	Test Method
Skin Time	5 Minutes	BS 5889
Tack Free Time	30 Minutes	ASTM C679
Tooling Time	10 Minutes	ASTM C679
Sag or Slump	Nil	BS 5889

### Cured Properties

Property	Mean Result Achieved	Test Method
Shore A Hardness	17-24	ASTM C 661
Modulus at 100% Elongation	0.3 MPa	ASTM D 412
Tensile Strength	1.0 MPa	ASTM D 412
Elongation at Rupture	500%	ASTM D 412
Peel Strength after UV through Glass	50N/25mm	BS 5889
Dynamic Movement Capacity	±25%	ASTM C 920
Accelerating Aging and Weathering	Excellent	ASTM C 792

### Temperature

	Minimum	Maximum
Application Temperature	6°C	50°C
Service Temperature	-40°C	150°C

Application of the sealant at + 5°C is permissible provided the surface to receive the silicone is dry and free of frost. The maximum service temperature listed is for transient temperature: the silicone sealant will deteriorate if subjected to these temperatures on a continuous basis

## Packaging

- The standard packaging for Sarlsson 168 All-Purpose is 300 ml cartridge.

## Sealant Application



## Limitation

Sarlsson 168 All-Purpose is NOT suitable for use in the following applications:

- As the sealant requires atmospheric humidity to cure, it will not cure in totally confined spaces where it does not have access to atmospheric humidity.
- Aquariums
- Adhering Mirrors
- Structural Glazing (Sarlsson 268 is recommended for Structural Glazing)
- Below Grade Applications
- All Stone's (We recommend the completion of a stain testing program before using any sealant on stone) Sarlsson 168A Marble and Granite is recommended for marble, granite (after stain test).
- Horizontal walkways
- Sealant may discolour copper & brass.
- Not recommended for use on polycarbonate sheeting.
- Do not clean or treat the sealant with materials, cleaning agents or solvents, that may affect or discolour the sealant, particularly during product curing.
- This silicone is not paintable.

## Health and Safety

Full product safety information required for safe use is not included in this data sheet. Before handling, read the separate Material Safety Data Sheet (MSDS) and packaging for safe use. In case of product emergency refer to product labelling or MSDS and contact phone numbers. A copy of the product MSDS is available from Sarlsson or its distributors.

## Important Notice for Users

Suggestions for use should not be taken as an inducement to infringe any particular patent.

## Product Details

Item Number	Size	Colour	Pack Quantity
<b>168111</b>	<b>300gm</b>	<b>Clear</b>	<b>24</b>
<b>168112</b>	<b>300gm</b>	<b>Grey</b>	<b>24</b>
<b>168113</b>	<b>300gm</b>	<b>White</b>	<b>24</b>

The representations and recommendations regarding the products are based on tests which we believe to be reliable. However, no guarantee of their accuracy can be made because of the great range of field conditions and variations encountered in raw materials, manufacturing equipment and methods. Thus, the products are sold with a limited warranty only, and on the condition that purchasers will make their own tests to determine the suitability of the product for their particular purposes. Under no circumstances will Saier Brothers Trading Pty Ltd be liable to anyone except for replacement of the products or refund of the purchase price.

